



Keystone Certifications, Inc.
 1790 Old Trail Road, Suite D
 Etters, PA 17404 / Phone 717-932-8500

Notice of Product Certification Authorization

National Fenestration Rating Council

Issued To:

Manufacturer: Dove Vinyl Windows
 Address: 767 San Souci Parkway
 Wilkes-Barre, PA 18702
 NFRC Code: DVW
 Cert Date: 10/28/2005

Certification Number

3580

Product Line Number

DVW - K - 013

The Following NFRC Product Line Has Been Authorized For Certification:

Model / Series: 6300 Repl / NC Picture
 Operator Type: FIXD
 Frame Type: VY
 Sash Type: N
 Exp. Date: 9/29/2009

Ratings Authorized For Certification:

Rating	Property	Authorized
NFRC 100	U-factor	<input checked="" type="checkbox"/>
NFRC 200	Solar Heat Gain Coefficient	<input checked="" type="checkbox"/>
NFRC 200	Visible Light	<input checked="" type="checkbox"/>
NFRC 400	Air Leakage	<input type="checkbox"/>
NFRC 500	Condensation Resistance	<input checked="" type="checkbox"/>

Conditions And Criteria For Product Certification Authorization:

Manufacturer Agrees To The Following Conditions And Criteria Per The NFRC PCP:

- 3.1A Products are marketed consistent to the simulated products.
- 3.1B Waiver requests shall be submitted to IA prior to marketing new products.
- 3.1C Only products with labels shall be considered certified.
- 3.1D Only products authorized for certification shall be labeled.
- 3.1E Manufacturer shall designate individual responsible for the proper labeling.
- 3.1F Manufacturer shall not use labels that are false, inaccurate or misleading.
- 3.2A Manufacturer shall maintain a documented in-plant quality control program.
- 3.2B Quality control records shall be maintained for 4 years.
- 3.2C Manufacturer shall have staff to properly inspect and maintain quality control records.
- 3.3A Manufacturer shall have temporary labels approved prior to printing.
- 3.3B, C Manufacturer agrees to the proper use of temporary and permanent labels.
- 3.5 Manufacturer agrees to obtain permission from NFRC to use the NFRC Certification Mark.

Attached are the Certification Authorization Reports printed from the NFRC database.

The Manufacturer is authorized to label the options listed in the reports.

Please notify Keystone of any errors or omissions within 10 days of receipt.

Authorized Signature: _____

Marcia P. Fulle

Date: _____

10-28-05

Due diligence was used in authorizing these products for certification. By accepting this report the licensee agrees to hold harmless and indemnify Keystone Certifications, Inc. from all claims or liabilities which may arise based on this certification authorization. Certification authorization is based on NFRC program requirements and simulation and test reports from accredited laboratories.

NFRC Product Certification Authorization Report



IA: Keystone Certifications, Inc.

Manufacturer: Dove Vinyl Windows
 Product Series: 6300 Series Replacement / New Construction Picture Window
 Simulation Lab: SATI
 Test Date: 9/29/2005
 Revised Date:
 Air Leakage:

Street: 767 Sans Souci Parkway
 Type: Fixed

City/State/Zip: Wilkes-Barre, PA 18706
 CPD Number: DWW-K-13

Simulation Report Date: 8/17/2005
 Initial Certification Date: 10/28/2005
 Expiration Date: 9/28/2009

Simulation Report Number: 58974.02-116-45
 Re-Certification Date:
 Print Date: 10/28/2005

Product ID	Configuration	Rating	U-Value	SHGC	Visible Transmittance	Acoustic Index	Light Transmittance	Light Glare	Light Reflection	Light Diffusion	Light Contrast	Light Color	Light Flicker	Light Strob	Light Flicker	Light Strob	Light Flicker	Light Strob	Light Flicker	Light Strob
00001	clr/clr - ds	VY/N	2	0.6250	CU-D	AIR	N	CL	0.45	0.58	0.52	48								
00001-00001	clr/clr - ds	VY/N	2	0.6250	CU-D	AIR	G	0.75	CL	0.45	0.52	0.55	48							
00001-00002	clr/clr - ds	VY/N	2	0.6250	CU-D	AIR	G	1.5	CL	0.45	0.46	0.48	48							
00002	035/clr - ds	VY/N	2	0.035 (2)	0.8250	CU-D	AIR	N	LE	0.32	0.30	0.55	62							
00002-00001	035/clr - ds	VY/N	2	0.035 (2)	0.8250	CU-D	AIR	G	0.75	LE	0.32	0.27	0.49	62						
00002-00002	035/clr - ds	VY/N	2	0.035 (2)	0.8250	CU-D	AIR	G	1.5	LE	0.32	0.24	0.43	62						
00003	035/arg/clr - ds	VY/N	2	0.035 (2)	0.8250	CU-D	ARG	N	LE	0.28	0.30	0.55	65							
00003-00001	035/arg/clr - ds	VY/N	2	0.035 (2)	0.8250	CU-D	ARG	G	0.75	LE	0.28	0.27	0.49	65						
00003-00002	035/arg/clr - ds	VY/N	2	0.035 (2)	0.8250	CU-D	ARG	G	1.5	LE	0.28	0.24	0.43	65						
00004	035/kry/clr - ds	VY/N	2	0.035 (2)	0.8250	CU-D	KRY	N	LE	0.27	0.30	0.55	66							
00004-00001	035/kry/clr - ds	VY/N	2	0.035 (2)	0.8250	CU-D	KRY	G	0.75	LE	0.27	0.27	0.49	66						
00004-00002	035/kry/clr - ds	VY/N	2	0.035 (2)	0.8250	CU-D	KRY	G	1.5	LE	0.27	0.24	0.43	66						
00005	clr/clr - ds	VY/N	2	0.6250	ZF-S	AIR	N	CL	0.44	0.58	0.52	46								
00005-00001	clr/clr - ds	VY/N	2	0.6250	ZF-S	AIR	G	0.75	CL	0.44	0.52	0.55	46							
00005-00002	clr/clr - ds	VY/N	2	0.6250	ZF-S	AIR	G	1.5	CL	0.44	0.48	0.48	46							
00006	035/clr - ds	VY/N	2	0.035 (2)	0.8250	ZF-S	AIR	N	LE	0.31	0.30	0.55	58							
00006-00001	035/clr - ds	VY/N	2	0.035 (2)	0.8250	ZF-S	AIR	G	0.75	LE	0.31	0.27	0.49	58						
00006-00002	035/clr - ds	VY/N	2	0.035 (2)	0.8250	ZF-S	AIR	G	1.5	LE	0.31	0.24	0.43	58						
00007	035/arg/clr - ds	VY/N	2	0.035 (2)	0.8250	ZF-S	ARG	N	LE	0.27	0.30	0.55	63							
00007-00001	035/arg/clr - ds	VY/N	2	0.035 (2)	0.8250	ZF-S	ARG	G	0.75	LE	0.27	0.27	0.49	63						
00007-00002	035/arg/clr - ds	VY/N	2	0.035 (2)	0.8250	ZF-S	ARG	G	1.5	LE	0.27	0.24	0.43	63						
00008	035/kry/clr - ds	VY/N	2	0.035 (2)	0.8250	ZF-S	KRY	N	LE	0.26	0.30	0.55	62							
00008-00001	035/kry/clr - ds	VY/N	2	0.035 (2)	0.8250	ZF-S	KRY	G	0.75	LE	0.26	0.27	0.49	62						
00008-00002	035/kry/clr - ds	VY/N	2	0.035 (2)	0.8250	ZF-S	KRY	G	1.5	LE	0.26	0.24	0.43	62						
00009	035/clr - ss - 1"	VY/N	2	0.035 (2)	0.7500	ZF-S	AIR	N	LE	0.31	0.30	0.55	59							
00009-00001	035/clr - ss - 1"	VY/N	2	0.035 (2)	0.7500	ZF-S	AIR	G	0.75	LE	0.31	0.27	0.49	59						
00009-00002	035/clr - ss - 1"	VY/N	2	0.035 (2)	0.7500	ZF-S	AIR	G	1.5	LE	0.31	0.24	0.43	59						
00010	035/arg/clr - ss - 1"	VY/N	2	0.035 (2)	0.7500	ZF-S	ARG	N	LE	0.28	0.30	0.55	62							
00010-00001	035/arg/clr - ss - 1"	VY/N	2	0.035 (2)	0.7500	ZF-S	ARG	G	0.75	LE	0.28	0.27	0.49	62						
00010-00002	035/arg/clr - ss - 1"	VY/N	2	0.035 (2)	0.7500	ZF-S	ARG	G	1.5	LE	0.28	0.24	0.43	62						
00011	035/kry/clr - ss - 1"	VY/N	2	0.035 (2)	0.7500	ZF-S	KRY	N	LE	0.26	0.30	0.55	62							
00011-00001	035/kry/clr - ss - 1"	VY/N	2	0.035 (2)	0.7500	ZF-S	KRY	G	0.75	LE	0.26	0.27	0.49	62						
00011-00002	035/kry/clr - ss - 1"	VY/N	2	0.035 (2)	0.7500	ZF-S	KRY	G	1.5	LE	0.26	0.24	0.43	62						
00012	035/035/clr - ss - 1"	VY/N	3	0.035 (2) / 0.035 (3)	0.35900	ZF-S	AIR	N	LE	0.27	0.25	0.45	64							
					0.3590	AIR														

NFRC Product Certification Authorization Report

IA: Keystone Certifications, Inc.

Manufacturer: Dove Vinyl Windows
 Product Series: 6300 Series Replacement / New Construction Picture Window

Street: 767 Sans Souci Parkway
 Type: Fixed

City/State/Zip: Wilkes-Barre, PA 18706
 CPD Number: DWW-K-13

Product ID	Configuration	Rating	U-Value	SHGC	Visible Transmittance	Acoustic Index	Light Transmittance	Light Glare	Light Reflection	Light Diffusion	Light Contrast	Light Color	Light Flicker	Light Strob	Light Flicker	Light Strob	Light Flicker	Light Strob	Light Flicker	Light Strob
00013	035/035/clr - ss - 1"	VY/N	3	0.035 (2) / 0.035 (3)	0.35900	ZF-S	AIR	G	0.75	LE	0.27	0.23	0.40	64						
					0.3590	AIR														
00013-00001	035/035/clr - ss - 1"	VY/N	3	0.035 (2) / 0.035 (3)	0.35900	ZF-S	AIR	G	1.5	LE	0.27	0.21	0.36	64						
					0.3590	AIR														
00014	035/arg/035/arg/clr - ss - 1"	VY/N	3	0.035 (2) / 0.035 (3)	0.35900	ZF-S	ARG	N	LE	0.23	0.26	0.45	68							
00015	035/arg/035/arg/clr - ss - 1"	VY/N	3	0.035 (2) / 0.035 (3)	0.35900	ZF-S	ARG	G	0.75	LE	0.24	0.23	0.40	68						
00015-00001	035/arg/035/arg/clr - ss - 1"	VY/N	3	0.035 (2) / 0.035 (3)	0.35900	ZF-S	ARG	G	1.5	LE	0.24	0.21	0.36	68						
					0.3590	ARG														
00016	035/kry/035/kry/clr - ss - 1"	VY/N	3	0.035 (2) / 0.035 (3)	0.35900	ZF-S	KRY	N	LE	0.20	0.26	0.45	73							
00017	035/kry/035/kry/clr - ss - 1"	VY/N	3	0.035 (2) / 0.035 (3)	0.35900	ZF-S	KRY	G	0.75	LE	0.21	0.23	0.40	71						
					0.3590	KRY														
00017-00001	035/kry/035/kry/clr - ss - 1"	VY/N	3	0.035 (2) / 0.035 (3)	0.35900	ZF-S	KRY	G	1.5	LE	0.21	0.21	0.36	71						
					0.3590	KRY														
08	00018	Test option 46.875x59	VY	3	0.035 (2) / 0.035 (5)	0.35900	ZF-S	KRY	N	LE	0.16	0.26	0.45							
						0.3590	KRY													

Baseline Information

Test Lab	Test Date	Test Size	Tested U-Value	Standard U-Value	Test Report Number
TATM	9/29/2005	46.875 X 59	0.17	0.16	58975.02-201-46

Comments:

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA Signature:

Keystone Certifications, Inc.

Scanning Separator Page - Product - NFRC Documents

Dove Vinyl Windows - NFRC - CAR

Category



Cust_ID



Model_Name

6300 Repl / NC Picture

CAR_NO



Rept_NO

58974.02-116-45-R1

Exp_Date

